

ICS 91.140
CCS P 40

CJ

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

CJ/T 241-2007

**Water meter for fine drinking water
(English Translation)**

Issued on: January 17, 2007

Implemented on: August 1, 2007

**Issued by: Ministry of Housing and Urban-Rural Development of the
People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the drinking water purification product terms and definitions, technical characteristics, metrological characteristics, test methods, inspection rules, marking, packaging, transportation and storage. This standard applies to common flow range of 0.6m³/h ~ 10m³/h, the maximum allowable working pressure (MAP) is greater than or equal to greater than 1MPa and the maximum allowable operating temperature (MAT) was measured at 30°C different levels of drinking water meter (hereinafter referred to as the meter).

Document data

International classification (ICS): 91.140.

Chinese classification (CCS): P40.

Estimated length of the Chinese original: 8,838 words.

Standards quoted by this document

GB/T 778.1-1996; GB/T 778.3-1996; GB 4208-1993; GB/T 7307-2001; GB/T 15464-1995; GB/T 17219-1998; CJ 3064; JB/T 9329-1999