

ICS 91.140.60
CCS P 42

CJ

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

CJ/T 255-2007

**Non-slam nozzle check valve
(English Translation)**

Issued on: June 5, 2007

Implemented on: December 1, 2007

**Issued by: Ministry of Housing and Urban-Rural Development of the
People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the Diversion quick closing check valve terminology and definitions, structure type, model, requirements, testing and test methods, inspection rules, marks, product brochures, packaging and storage of basic requirements. This standard used in the DN DN25mm ~ DN800mm, nominal pressure is less than or equal to PN2. 5MPa, medium temperature is less than or equal to 65°C, the medium is water or physical and chemical properties similar to water pipes Diversion ratio check valves.

Document data

International classification (ICS): 91.140.60.

Chinese classification (CCS): P42.

Estimated length of the Chinese original: 17,163 words.

Standards quoted by this document

GB/T 1047; GB/T 1048; GB/T 1239.6-1992; GB/T 1804-2000; GB/T 3098; GB/T 3280; GB/T 6739-2006; GB/T 7306.2; GB/T 8923-1988; GB/T 9286-1998; GB/T 9969.1; GB 12220; GB/T 12225; GB/T 12226; GB/T 12227; GB/T 13927; GB/T 17219; GB/T 17241.6; GB/T 17241.7; HG/T 3091; JB/T 308; JB/T 7928; JB/T 9092-1999