

ICS 23.060.99
CCS J 16

CJ

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

CJ/T 344-2010

**Backflow freventer with intermediate atmospheric vent
(English Translation)**

Issued on: August 3, 2010

Implemented on: January 1, 2011

**Issued by: Ministry of Housing and Urban-Rural Development of the
People's Republic of China**

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the intermediate chamber air partition type backflow prevention device structure type and parameters, requirements, performance requirements, test methods, inspection rules, marking, packaging and storage. This standard applies to nominal pressure of PN 1. 0MPa ~ 1. 6MPa, nominal size DN15 mm ~ DN300mm intermediate chamber air partition type backflow prevention device.

Document data

International classification (ICS): 23.060.99.

Chinese classification (CCS): J16.

Estimated length of the Chinese original: 12,110 words.

Standards quoted by this document

GB/T 1047; GB/T 1048; GB/T 7307-2001; GB/T 8464; GB/T 9113.1; GB/T 9124; GB/T 12220; GB/T 12225; GB/T 12226; GB/T 12227; GB/T 12229; GB/T 12230; GB/T 13927; GB/T 13932; GB/T 15117; GB/T 17219; GB/T 17241.6; GB/T 17241.7; JB/T 308; JB/T 5300; JB/T 7748; JB/T 7927; JB/T 7928; JB/T 8937