

ICS 29.240.20
CCS K 47

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1007-2006

**Live wording. Guidelines for the installation of transmission
line conductors and earthwires. Stringing equipment and
accessory items**

(English Translation)

Issued on: September 14, 2006

Implemented on: March 1, 2007

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the electrified wires overhead transmission line installation, ground and insulator strings and fittings, the installation tools and equipment selection principles and technical requirements. This standard specifies the grounding procedures to ensure that work equipment and staff from injury induced current. This standard applies to 110kV and above transmission lines. For up to 35kV distribution lines, most of the technical requirements and test requirements are also applicable.

Document data

International classification (ICS): 29.240.20.

Chinese classification (CCS): K47.

Estimated length of the Chinese original: 38,334 words.

Adopted international standard: IEC 61328-2003, IDT.

Standards quoted by this document

GB/T 2900.51; GB/T 2900.55; GB/T 14286; DL/T 879