

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1027-2006

Replacing NDGJ 89-1989

**Acceptance test specification of industrial cooling tower
(English Translation)**

Issued on: December 17, 2006

Implemented on: May 1, 2007

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the industrial circulating water wet cooling tower thermal performance, noise and loss of water drops floating uniform test procedures, and methods of measurement of various parameters, test data processing method and the test results of the evaluation. This standard applies to new or renovated wet mechanical ventilation and natural ventilation of industrial circulating water cooling towers acceptance testing. Non-acceptance of the nature of the cooling tower test can refer to this standard. This standard does not apply to all kinds of air-cooling towers and chimneys and cooling towers of smoke in building cooling towers acceptance testing.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 26,211 words.

Supersedes the earlier edition NDGJ 89-1989.

Standards quoted by this document

GB/T 3785; GB/T 7190.1; GB/T 7190.2; GB 12348; GB/T 12349; GB/T 50050; DL 5000