

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1093-2018

Replacing DL/T 1093-2008

**Guide for reactance method to detect and diagnose winding
deformation of power transformer**

电力变压器绕组变形的电抗法检测判断导则

(English Translation)

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the principle of power transformer winding deformation reactance detection, winding parameter detection, winding deformation judgment and so on. This standard applies to concentric winding power transformers of 35kV and above, and other concentric winding transformers for special purposes.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 14,165 words.

Supersedes the earlier edition DL/T 1093-2008.

Standards quoted by this document

GB/T 1094.1-2013; GB/T 1094.5-2018; GB/T 2900.77; DL/T 911-2016