

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1354-2014

**The method of flash point of power oil by microscale
continuously closed cup tester**

电力用油闭口闪点测定微量常闭法

(English Translation)

Issued on: October 15, 2014

Implemented on: March 1, 2015

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This Standard specifies the power of oil closed flash point assay using micro NC basic requirements. This Standard applies to transformer oil, turbine oil or other flash point oil sample of 40°C ~ 250°C.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 10,184 words.

Standards quoted by this document

GB/T 261; GB/T 6683; GB/T 7597; GB/T 15000.3; GB/T 15000.7; GB/T 15000.8; ASTM D 6450