

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1422-2015

**The gradational standard of microstructure aging for 18Cr-8Ni
serials austenitic stainless steel boiler tubes**

18Cr-8Ni系列奥氏体不锈钢锅炉管显微组织老化评级标准

(English Translation)

Issued on: April 2, 2015

Implemented on: September 1, 2015

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the rating method for microstructure aging of 18Cr-8Ni series austenitic stainless steel boiler tubes for thermal power plants. This standard applies to 18Cr-8Ni series of austenitic stainless steel manufacturing superheater and reheater tube in high temperature service after the degree of organization to assess the degree of aging. 18Cr-8Ni series of austenitic stainless steel, including 07Cr19Ni10, 07Cr19Ni11Ti, 07Cr18Ni11Nb, 08Cr18Ni11NbFG Chinese brands of steel and chemical composition of these steel with the same or similar national steel of other countries.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 19,170 words.

Standards quoted by this document

GB 5310; GB/T 13298; DL/T 884