

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1427-2015

**Gas turbine heat recovery steam generators performance test
codes**

联合循环余热锅炉性能试验规程
(English Translation)

Issued on: April 2, 2015

Implemented on: September 1, 2015

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard applies to the recovery of waste heat from the exhaust gas turbine. The method of this standard can also be used for the performance test of the following other waste heat recovery devices: 1) waste heat recovery unit for heating only water; 2) waste heat recovery unit for other working fluid other than water; 3) other than the waste heat of the gas turbine Heat source of the waste heat recovery device; 4) can be used fresh air burning waste heat boiler. 2) auxiliary equipment such as pump and fan performance; 3) deaerator performance; 4) equipment noise; 5) gas (1) the main function of the gas Pollutant emissions; 6) steam purity.

Document data

Chinese classification (CCS): F22.

Estimated length of the Chinese original: 115,172 words.

Adopted international standard: ASMEPTC 4.4-2008, IDT.