

ICS 77.040.20
CCS H 26

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1452-2015

Ultrasonic guided waves testing for pipes in power plant

火力发电厂管道超声导波检测

(English Translation)

Issued on: April 2, 2015

Implemented on: September 1, 2015

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard stipulates the general requirements, detection methods, etc., of manual circumferential contact piezoelectric ultrasonic guided wave detection. This standard applies to the outer diameter of 25mm ~ 1020mm, wall thickness of 3mm ~ 80mm of steel pipe base metal and internal and external surface defects detection.

Document data

International classification (ICS): 77.040.20.

Chinese classification (CCS): H26.

Estimated length of the Chinese original: 14,118 words.

Standards quoted by this document

GB/T 5777; GB/T 12604.1; GB/T 12604.6; DL/T 675; DL 5009.1