

ICS 27.060.01
CCS J 98

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1495-2016

**Determination of water-soluble fluoride of FGD gypsum and
slurry in thermal power plants**

火力发电厂脱硫石膏及浆液中水溶性氟离子的测定

(English Translation)

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the thermal power plant desulfurization gypsum slurry and the determination of water-soluble ions in the atmosphere. This standard is applicable to the determination of water-soluble fluoride ion in gypsum and slurry of thermal power plant. The detection limit of this method is 0.10mg/L.

Document data

International classification (ICS): 27.060.01.

Chinese classification (CCS): J98.

Estimated length of the Chinese original: 7,726 words.

Standards quoted by this document

GB/T 5482-2012; GB/T 6682