

ICS 13.040.01
CCS Z 25

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1520-2016

**Specifications for fine particles (PM_{2.5}) monitoring in the
thermal power plants-gravimetric method**

火电厂烟气中细颗粒物 (PM_{2.5})测试技术规范 重量法

(English Translation)

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies a manual test method for the mass concentration of fine particulate matter (PM_{2.5}) in flue gas of thermal power plants. This standard is applicable to the testing of PM_{2.5} in low concentration flue gas of thermal power plant (the average mass concentration of dry flue gas particulate in the standard state is less than 40mg/m³ in half hour). The detection limit of this standard is 0.150mg/m³ (ambient air as sample, sampling volume is 2m³).

Document data

International classification (ICS): 13.040.01.

Chinese classification (CCS): Z25.

Estimated length of the Chinese original: 18,136 words.

Standards quoted by this document

GB/T 16157; HJ 93; HJ/T 194; HJ 618; ISO 12141; ISO/IEC 17025; ISO 23210