

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1534-2016

**Methods of UHF partial discharge detection in oil-immersed
power transformers
(English Translation)**

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the UHV detection method of partial discharge of oil-immersed power transformers (reactors), which mainly includes the functional requirements, detection and positioning technical requirements, signal characteristics and analysis methods of detection devices. This standard is applicable to the detection of partial discharges of oil-immersed power transformers (reactors) at 110 (66) kV and above.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 12,152 words.

Standards quoted by this document

GB/T 7354; GB 26860; GB 26861