

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1539-2016

**Selection guide to the high-voltage bushings for power
transformers (reactors)
(English Translation)**

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the selection principles, technical requirements, test items and test methods, marking, packaging, transportation and storage of bushings for power transformers (including converter transformers and reactors). This standard applies to power transformers with a rated voltage of not less than 12kV casing.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 24,240 words.

Standards quoted by this document

GB/T 507; GB/T 2900.5; GB/T 4109-2008; GB/T 4585; GB/T 5273; GB/T 5654; GB/T 7601; GB/T 13026; GB/T 17623; GB/T 19519; GB/T 21429; GB/T 22674-2008; GB/T 23752; GB/T 26218.1-2010; GB/T 26218.2-2010; DL/T 859; IEC 61463