

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1540-2016

**Measurement methods of operating vibration for and above
oil-immersed AC reactor(transformer)
(English Translation)**

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the measurement method of the vibration generated when the AC oil immersed reactor (transformer) is operated. This standard is applicable to AC oil-immersed reactors (transformers) of 110 (66) kV and above. Other occasions, the vibration measurement can refer to this standard.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 11,144 words.

Standards quoted by this document

GB/T 1094.6-2011; GB/T 2298-2010; SJ/Z 9145-1987; ISO 2041-2009