

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1541-2016

**Specifications of power transformer neutral point DC limit
(isolation) devices
(English Translation)**

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the conditions of use, technical performance parameters, construction, testing, and marking, packaging, transportation and storage of the neutral point DC current limiting device (hereinafter referred to as "current limiting device") of the power transformer and its accessory equipment And other aspects of the technical requirements. This standard applies to AC 220kV and above voltage level power transformer neutral point series connection of (limit) flow device. 110kV voltage level can refer to the implementation.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 16,162 words.

Standards quoted by this document

GB 1094.3; GB/T 1094.6; GB/T 4109; GB/T 5273; GB/T 7251.8; GB/T 8287.1; GB/T 8287.2; GB/T 12944; JB/T 10777