

ICS 29.240.99
CCS K 49

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1561-2016

**Calibration specification of arresters monitoring device
(English Translation)**

Issued on: January 7, 2016

Implemented on: June 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2

What this standard covers

This standard specifies the calibration conditions of the arrester monitoring device, calibration methods and calibration results of the treatment and re-calibration interval requirements. This standard applies to the laboratory and the field environment of metal oxide surge arrester on-line monitoring device (hereinafter referred to as the monitoring device) calibration work. This standard does not apply to the arrester discharge counter calibration.

Document data

International classification (ICS): 29.240.99.

Chinese classification (CCS): K49.

Estimated length of the Chinese original: 19,166 words.