

ICS 27.100
CCS F 29

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1568-2016

**Guide for field test of converter valve
(English Translation)**

Issued on: February 5, 2016

Implemented on: July 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard stipulates the field test items, test period, test requirements, test methods and test abnormal handling measures for the converter valve of DC power transmission with voltage class of degC 800kV and below. This standard applies to the HVDC converter station converter valve equipment field test, the annual maintenance test. This standard does not apply to the type valve device test, factory test and return to factory test. The converter station in the field test can be based on this standard, combined with equipment, technical conditions, operating status, etc. to add the appropriate test content.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F29.

Estimated length of the Chinese original: 23,290 words.

Standards quoted by this document

GB/T 13498; GB 26860