

ICS 29.020
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1575-2016

**Partial discharge measuring system for 6kV??35kV power
cables based on oscillating wave voltage
(English Translation)**

Issued on: February 5, 2016

Implemented on: July 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the composition, conditions of use, performance requirements, inspection methods, inspection rules, marking, packaging, transportation and storage of 6kV ~ 35kV cable sine wave partial discharge measurement system. This standard is applicable to the system of measuring and locating partial discharge faults of 6kV ~ 35kV cables by means of oscillation wave voltage method, which can be used as the basis for the design, production, testing, use, maintenance and arbitration of the system.

Document data

International classification (ICS): 29.020.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 15,135 words.

Standards quoted by this document

GB/T 191-2008; GB 4208-2008; GB 4793.1-2007; GB/T 6587-2012; GB/T 7354-2003; GB/T 17626.12; GB/T 17626.34; GB/T 17626.9; GB/T 17626.10; GB/T 17626.11; GB/T 17626.1; GB/T 17626.13; GB/T 17626.14; GB/T 17626.16; GB/T 17626.17; GB/T 17626.2; GB/T 17626.27; GB/T 17626.28