

ICS 27.100
CCS F 29

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1582-2016

**Guide for instruments test of HVDC valve cooling system
(English Translation)**

Issued on: February 5, 2016

Implemented on: July 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the high voltage direct current transmission system valve cold system temperature meter, conductivity meter, flow meter, liquid level meter, pressure gauge (including differential pressure gauge) detection conditions, testing equipment, testing methods, testing and evaluation aspects guide. This guideline is suitable for high voltage direct current transmission system valve cold system instrumentation detection.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F29.

Estimated length of the Chinese original: 13,194 words.

Standards quoted by this document

GB/T 1226; GB/T 17214.3-2000; JJF 1001; JJF 1183; JJG 376; JJG 971; JJG 1029