

ICS 29.240.30
CCS K 32

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1584-2016

**Field test code of 1000kV series capacitor installation
(English Translation)**

Issued on: February 5, 2016

Implemented on: July 1, 2016

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the field test items, test methods, test contents and evaluation requirements of 1000kV series capacitor compensation device (referred to as series compensation device or series compensation). Field tests include equipment transfer test, preventive test and sub-system commissioning, system commissioning, commissioning. This standard does not include the relevant part of the control test. This standard applies to the new or rebuilt 1000kV series capacitor compensation device field test, other voltage levels can refer to the implementation.

Document data

International classification (ICS): 29.240.30.

Chinese classification (CCS): K32.

Estimated length of the Chinese original: 36,382 words.

Standards quoted by this document

GB 311.1; GB/T 6115.1-2008; GB/T 6115.2-2002; GB 11032-2010; GB/T 14285-2006; GB/T 15145-2008; GB/T 15972.40; GB/T 20840.8; GB 50150-2006; DL/T 365-2010; DL/T 366-2010; DL/T 474.5-2006; DL/T 596-1996; DL/T 627-2012; DL/T 720-2013; DL/T 995-2006; DL/T 1000