

ICS 27.100
CCS K 51

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1628-2016

**Specification for excitation transformers of hydro turbine
generator**

(English Translation)

Issued on: December 5, 2016

Implemented on: May 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the technical requirements of excitation transformers, inspection rules, test methods. This standard applies to synchronous three-phase (group) capacity of not more than 16 000kVA, the maximum voltage not higher than 40.5kV synchronous generator excitation dry-type transformers (group) (hereinafter referred to excitation excitation).

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): K51.

Estimated length of the Chinese original: 11,198 words.

Standards quoted by this document

GB/T 191; GB/T 1094.11; GB/T 7409.3; GB/T 11021; GB/T 18494.1