

ICS 29.240
CCS F 23

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1685-2017

**Guide for condition evaluation of oil-immersed power
transformers (reactors)
(English Translation)**

Issued on: March 28, 2017

Implemented on: August 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the status information classification, status evaluation and classification, basic requirements for status evaluation, quantitative standards for status variables, and components and overall evaluation methods for AC oil-immersed transformers (reactors) during operation. This standard is applicable to AC oil-immersed transformers (reactors) with a system voltage rating of 110(66)kV to 750kV.

Document data

International classification (ICS): 29.240.

Chinese classification (CCS): F23.

Estimated length of the Chinese original: 22,229 words.

Standards quoted by this document

DL/T 393-2010; DL/T 664; DL/T 984; DL/T 1684-2017