

ICS 29.240
CCS F 23

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1690-2017

**Guide for condition evaluation of current transformers
(English Translation)**

Issued on: March 28, 2017

Implemented on: August 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the classification of state information, the classification of state evaluation, the basic requirements for state evaluation, the quantitative criteria for state quantities, and the overall evaluation method for current transformers in operation. This standard applies to AC current transformers with a system voltage rating of 110 (66) kV to 500 kV.

Document data

International classification (ICS): 29.240.

Chinese classification (CCS): F23.

Estimated length of the Chinese original: 11,197 words.

Standards quoted by this document

DL/T 393-2010; DL/T 664; DL/T 1691