

ICS 17.220
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1694.7-2020

**Calibration specification for high voltage testing instruments -
Part 7: Integrated protection measuring control devices.
Electrical measuring
(English Translation)**

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the measurement characteristics, calibration conditions, calibration items, calibration methods and recalibration time requirements of the electrical measurement part of the comprehensive protection measurement and control device (hereinafter referred to as the comprehensive protection device). This standard applies to the calibration of the electrical measurement part of the comprehensive protection device for power system applications of 35kV and below.

Document data

International classification (ICS): 17.220.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 18,115 words.

Standards quoted by this document

JJG 596; NB/T 42124