

ICS 270.100
CCS F 22

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1699-2017

**Installation acceptance code for heat recovery steam generator
of gas-steam combined cycle unit
(English Translation)**

Issued on: March 28, 2017

Implemented on: August 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the essentials and technical requirements for the installation and acceptance of the gas-steam combined cycle unit waste heat boiler (abbreviated as the waste heat boiler). This standard is applicable to gas turbine waste heat boilers with gas turbine ISO operating conditions with a simple cycle output of 15MW to 300MW. The other capacity gas turbine heat recovery boiler can refer to the implementation.

Document data

International classification (ICS): 270.100.

Chinese classification (CCS): F22.

Estimated length of the Chinese original: 35,360 words.

Standards quoted by this document

GB 50026; GB 50204; GB 50205; GB 50231; GB 50275; GB 50278; DL 612; DL 647; DL/T 678; DL/T 794; DL 855; DL/T 869; DL/T 889; DL/T 1113; DL/T 5072; DL 5190.2-2012; DL 5190.3; DL 5190.4; DL 5190.5; DL 5190.6; DL 5190.7-2012; DL/T 5210.2-2009; DL/T 5210.5-200