

ICS 29.240
CCS F 23

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1701-2017

**Guide for condition evaluation of disconnecter and earthing
switch**

(English Translation)

Issued on: March 28, 2017

Implemented on: August 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard stipulates the status information classification, status assessment and classification, basic requirements for condition evaluation, quantification criteria of state quantity, and parts and overall evaluation methods for isolation switch and grounding switchgear during operation. This standard is applicable to open AC disconnectors and grounding switchgears with a system voltage rating of 110(66)kV to 750kV.

Document data

International classification (ICS): 29.240.

Chinese classification (CCS): F23.

Estimated length of the Chinese original: 18,164 words.

Standards quoted by this document

DL/T 393-2010; DL/T 664; DL/T 1700-2017