

ICS 29.240.01
CCS F 20

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1788-2017

**Field calibrating specifications for HVDC instrument
transformers**

(English Translation)

Issued on: December 27, 2017

Implemented on: June 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the measurement performance, calibration conditions, calibration items and methods of the high-voltage DC transformer, the expression of the verification results and the calibration period. This standard is applicable to DC currents for DC transmission systems with voltage levels of degC1100kV and below. Field calibration of transformers and DC voltage transformers.

Document data

International classification (ICS): 29.240.01.

Chinese classification (CCS): F20.

Estimated length of the Chinese original: 20,229 words.

Standards quoted by this document

GB/T 20840.8-2007; GB/T 26216.1-2010; GB/T 26216.2-2010; GB/T 26217-2010