

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1806-2018

**Guide for the choice of insulation board and component in
oil-immersed transformers
(English Translation)**

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the classification and selection principles, technical requirements, inspection rules, marking, packaging, transportation and storage of insulating paperboard and insulating parts for oil-immersed power transformers and reactors (hereinafter referred to as transformers). This standard applies to oil-immersed power transformers and converter transformers with voltage levels of 110 (66) kV to 750 kV.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 12,139 words.

Standards quoted by this document

GB/T 1410; GB/T 1548; GB/T 2900.5-2013; GB/T 19264.1; GB/T 19264.2-2013; GB/T 19264.3; JB/T 8318-2007; DIN 52352; IEC 60763-2-2007