

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1808-2018

**Guide for turn-to-turn overvoltage test of air-core reactors on
site**

(English Translation)

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the basic test circuit and equipment, test requirements, test procedures, judgment of test results, on-site records and report preparation for the on-site handover test of dry-type air-core reactors and diagnostic tests. This standard applies to dry-type air-core reactors with a voltage level of 6kV to 35kV.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 11,164 words.

Standards quoted by this document

GB/T 1094.6-2011