

ICS 29.180
CCS K 41

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1811-2018

**Guide for selection of the natural esters insulating oil for power
transformers**
(English Translation)

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the selection requirements, on-site acceptance and treatment of unused natural ester insulating oil for power transformers, performance requirements after injection into transformers, maintenance treatment, safety and environmental requirements, etc. This standard applies to the selection, acceptance and maintenance of natural cool insulating oil for power transformers (reactors) of 220kV and below.

Document data

International classification (ICS): 29.180.

Chinese classification (CCS): K41.

Estimated length of the Chinese original: 16,169 words.

Standards quoted by this document

GB/T 261; GB/T 264; GB/T 265; GB/T 507; GB/T 1884; GB/T 2900.5; GB/T 2900.95; GB/T 3535; GB/T 3536; GB/T 5654; GB/T 6541; GB/T 7597; GB/T 7600; GB/T 21801; GB/T 21802; GB/T 21856; GB/T 25961; DL/T 419; NB/T 42140; NB/SH/T 0811; NB/SH/T 0812; SH/T 0803