

ICS 27.100
CCS F 20

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1850-2018

**Guideline of order and acceptance for hydraulic control check
butterfly valves of water pump outlet in power station
(English Translation)**

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the ordering and acceptance requirements for liquid control check butterfly valves. This standard applies to the nominal size DN400 ~ DN3000, the nominal pressure is less than or equal to PN10, installed in the power plant circulating water pump and cooling water pump outlet flange connection liquid control check butterfly valve.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F20.

Estimated length of the Chinese original: 22,210 words.

Standards quoted by this document

GB/T 700; GB/T 1047; GB/T 1048; GB/T 1220; GB/T 1591; GB/T 2352; GB/T 3766; GB/T 4208; GB/T 4237; GB 5226.1; GB/T 7935; GB/T 9112; GB/T 9113; GB/T 9115; GB/T 9124; GB/T 12221; GB/T 12224; GB/T 12227; GB/T 12229; GB/T 12238; GB/T 12465; GB/T 13927