

ICS 29.240.01
CCS F 21

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 1911-2018

**Technical specification of test device for smart substation
monitoring and control system
(English Translation)**

Issued on: December 25, 2018

Implemented on: May 1, 2019

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the general requirements, working conditions, interfaces, test functions, performance, packaging, transportation, storage, and requirements for signs and labels of intelligent substation monitoring system test devices. This standard applies to the design, manufacture, inspection and acceptance of intelligent substation monitoring system test equipment.

Document data

International classification (ICS): 29.240.01.

Chinese classification (CCS): F21.

Estimated length of the Chinese original: 16,137 words.

Standards quoted by this document

GB/T 2423.1; GB/T 2423.2; GB/T 2423.4; GB/T 2423.22; GB/T 4208; GB/T 11287; GB/T 14537; GB/T 14598.27; GB/T 17626.2; GB/T 17626.3; GB/T 17626.4; GB/T 17626.12; GB/T 30155; DL/T 634.5101; DL/T 634.5104; DL/T 860.71; DL/T 860.81; DL/T 860.93; DL/T 860.905