

ICS 27.060
CCS J 98

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2051-2019

**Performance test code for air heaters
(English Translation)**

Issued on: November 4, 2019

Implemented on: May 1, 2020

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the test methods, test procedures and requirements for testing various performance indicators of power plant boiler air preheaters, as well as the correction methods for these performance indicators under different working conditions. This standard applies to power station boiler air preheaters and heaters with no phase change in the heating medium, but not to direct-fired air preheaters, flue gas/flue gas heaters, and phase change heaters and electric heating Air preheater.

Document data

International classification (ICS): 27.060.

Chinese classification (CCS): J98.

Estimated length of the Chinese original: 47,420 words.

Standards quoted by this document

GB/T 10184; IAPWS IFC-97