

ICS 27.100
CCS F 29

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2091-2020

**Determination of condensable particulate matter in flue gas of
coal-fired power plant -- Dry impinger method**

(English Translation)

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the test methods and requirements for condensable particulate matter in the flue gas of coal-fired power plants. The detection limit of the method is 0.5mg/m³ (take ambient air as the sample, and the sampling volume is 1m³). This standard is applicable to the test of the concentration of condensable particulate matter in the flue gas when the flue gas temperature exceeds 30degCC.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F29.

Estimated length of the Chinese original: 8,847 words.

Standards quoted by this document

GB/T 6682; GB/T 16157; HJ/T 47; HJ/T 397; HJ 656