

ICS 29.160.40
CCS K 52

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2092-2020

**Specification for electrical start-up test of fossil power
generating units
(English Translation)**

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the inspection, electrical test items and test content before the electrical start-up test during the start-up process of the thermal power generating set. This standard applies to thermal power generating units such as steam turbine generators and gas turbine generators of 100MW and above. Thermal power generating units below 100MW can be implemented by reference.

Document data

International classification (ICS): 29.160.40.

Chinese classification (CCS): K52.

Estimated length of the Chinese original: 18,116 words.

Standards quoted by this document

GB/T 1029; GB/T 7409.3; GB 50150; DL/T 843; DL/T 1166; DL/T 1525; DL/T 1768; DL/T 5294; DL/T 5437