

ICS 29.240.99
CCS K 43

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2113-2020

**Test specification for hybrid HVDC circuit-breakers
(English Translation)**

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the test items, methods and requirements for hybrid high-voltage DC circuit breakers (hereinafter referred to as "circuit breakers"), and is limited to electrical type tests and routine tests. This standard is applicable to circuit breakers designed and installed indoors and operating in high-voltage DC transmission systems of various voltage levels from 100kV to 500kV.

Document data

International classification (ICS): 29.240.99.

Chinese classification (CCS): K43.

Estimated length of the Chinese original: 18,133 words.

Standards quoted by this document

GB/T 1984-2014; GB/T 11022-2011; GB/T 11032; GB/T 16927.1; GB/T 20990.1-2007;
GB/T 21419-2013; GB/T 22389