

ICS 01.040.29
CCS F 20/29

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2115-2020

**Testing technical specification for voltage monitor
(English Translation)**

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the inspection category and period, inspection conditions, inspection requirements, inspection methods and processing of inspection results for voltage monitors. This standard can be used as the basis for the design, development, manufacturing, testing and operation of voltage monitors. For inspection of other automated terminals or devices with voltage deviation monitoring and statistical functions, refer to this standard.

Document data

International classification (ICS): 01.040.29.

Chinese classification (CCS): F20/29.

Estimated length of the Chinese original: 30,345 words.

Standards quoted by this document

GB/T 2423.5; GB/T 2423.10; GB/T 2828.2; GB/T 4208; GB 4793.1; GB/T 5169.11; GB/T 6587; GB/T 12113; GB/T 12325; GB/T 17626.2; GB/T 17626.3; GB/T 17626.4; GB/T 17626.5; GB/T 17626.18; DL/T 478; DL/T 500