

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 2142-2020

**Performance test code on indirect air-cooled system
(English Translation)**

Issued on: October 23, 2020

Implemented on: February 1, 2021

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the basic principles and requirements such as the arrangement of measurement points, instrument selection, test procedures and test data processing for the performance test of the indirect air cooling system of thermal power plants. This standard is applicable to the performance acceptance test of the steam turbine indirect air cooling system of newly built or renovated (expanded) power plants, as well as the operation performance test and performance diagnosis test of the steam turbine indirect air cooling system that has been in operation for many years.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 31,371 words.

Standards quoted by this document

GB/T 2624.1; GB/T 2624.2; GB/T 2624.3; GB/T 2624.4; GB/T 12348; GB/T 37753; DL/T 244