

ICS 19.080  
CCS K 40

**DL**

**INDUSTRY STANDARD OF THE  
PEOPLE'S REPUBLIC OF CHINA**

**DL/T 2183-2020**

---

**Test guide for transient behaviour of DC current transformers  
for DC transmission system  
(English Translation)**

**Issued on: October 23, 2020**

**Implemented on: February 1, 2021**

---

**Issued by: National Energy Administration**

## Table of Contents

|                                         |   |
|-----------------------------------------|---|
| What this standard covers .....         | 1 |
| Document data .....                     | 2 |
| Standards quoted by this document ..... | 3 |

### What this standard covers

This standard specifies the test items, general test conditions, test equipment and test methods for the transient test of DC current transformers for DC transmission (hereinafter referred to as DC current transformers). This standard applies to transient tests of DC current transformers with voltage levels of degC1100kV and below.

### Document data

International classification (ICS): 19.080.

Chinese classification (CCS): K40.

Estimated length of the Chinese original: 12,198 words.

### Standards quoted by this document

GB/T 20840.6-2017; GB/T 20840.8-2007; GB/T 26216.1-2019; GB/T 26216.2-2019