

ICS 29.040.01
CCS F 23

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 352-2019

Replacing DL/T 352-2010

**Guidelines for maintenance of HVDC switches
(English Translation)**

Issued on: November 4, 2019

Implemented on: May 1, 2020

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the maintenance items, cycle and technical requirements for DC circuit breakers of converter stations based on high-power thyristors of degC400kV and above. This standard is applicable to the on-site daily inspection and routine inspection of five types of DC circuit breakers, such as neutral bus switch, metal return transfer switch, neutral bus grounding switch, earth return transfer switch and bypass switch, which cut off the load current when switching operation modes. Overhaul, special overhaul. This standard does not apply to flexible DC transmission circuit breakers that directly cut off DC fault currents.

Document data

International classification (ICS): 29.040.01.

Chinese classification (CCS): F23.

Estimated length of the Chinese original: 17,124 words.

Supersedes the earlier edition DL/T 352-2010.

Standards quoted by this document

GB/T 1984; GB 26860; DL/T 273-2012; DL/T 345; DL/T 596-1996; DL/T 664