

ICS 29.240
CCS F 23

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 354-2019

Replacing DL/T 354-2010

**Guidelines of maintenance for converter transformers and
smoothing reactors
(English Translation)**

Issued on: November 4, 2019

Implemented on: May 1, 2020

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the maintenance items, periods and requirements for converter transformers and smoothing reactors with voltage levels of degC1100kV and below. This standard takes the oil-immersed smoothing reactor as an example to introduce, and the dry smoothing reactor is implemented by reference. This standard is applicable to daily maintenance, routine maintenance and special maintenance of converter transformers and oil-immersed smoothing reactors with voltage levels of degC1100kV and below. This standard does not apply to the overhaul work that is returned to the factory.

Document data

International classification (ICS): 29.240.

Chinese classification (CCS): F23.

Estimated length of the Chinese original: 18,170 words.

Supersedes the earlier edition DL/T 354-2010.

Standards quoted by this document

GB/T 7595; GB 26860; DL/T 273; DL/T 573; DL/T 574; DL/T 664; DL/T 722