

ICS 29.120.40
CCS K 43

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 406-2010

Replacing DL/T 406-1991

**Specification for automatic line sectionalizers for AC systems
(English Translation)**

Issued on: January 9, 2011

Implemented on: May 1, 2011

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the rated AC automatic subsection, the structure and design of two test face, use, transport material, storage, installation, operation and maintenance requirements. This standard applies to the rated voltage of 12kV, the frequency of the power system 50Hz string running outdoor AC automatic subsection (hereinafter referred to as slicer). This standard does not apply to fire, explosion, chemical corrosion and severe vibration dangerous places to use the slicer.

Document data

International classification (ICS): 29.120.40.

Chinese classification (CCS): K43.

Estimated length of the Chinese original: 18,178 words.

Supersedes the earlier edition DL/T 406-1991.

Standards quoted by this document

GB/T 2423.10; DL/T 486; DL/T 403; DL/T 593-2006