

ICS 27.100
CCS F 20

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 439-2018

Replacing DL/T 439-2006

**The technical guide for high-temperature bolt of fossil-fired
power plant
(English Translation)**

Issued on: April 3, 2018

Implemented on: July 1, 2018

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard stipulates the selection, inspection contents, methods and treatment measures for high temperature fasteners in thermal power plants, and puts forward requirements for the fastening and disassembly of bolts. This standard is applicable to the inspection and treatment of bolts, nuts and washers for cylinders, valves, valves and steam pipe flanges with a working temperature above 400 degCC. For fasteners with a working temperature of 400 degC C and below, refer to the implementation.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F20.

Estimated length of the Chinese original: 18,130 words.

Supersedes the earlier edition DL/T 439-2006.

Standards quoted by this document

GB/T 2; GB/T 3; GB/T 90.1; GB/T 90.2; GB/T 98; GB/T 196; GB/T 197; GB/T 226; GB/T 231.1; GB/T 5779.1; GB/T 5779.2; GB/T 6394; GB/T 17394.1; NB/T 47013.4; NB/T 47013.5; DL/T 441; DL/T 694; DL/T 884; DL/T 1719; DL/T 1845