

ICS 29.240.01
CCS F 20

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 501-2017

Replacing DL/T 501-1992

**Methods for measurement of audible noise from high voltage
overhead transmission line**

高压架空输电线路可听噪声测量方法

(English Translation)

Issued on: August 2, 2017

Implemented on: December 1, 2017

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the measurement method for audible noise of high-voltage overhead transmission lines, so as to correctly evaluate the characteristics of audible noise of high-voltage overhead transmission lines. This standard is applicable to short-term and long-term measurement of audible noise of AC and DC overhead transmission lines. The measured quantity is A sound level, cumulative sound level, 31.5Hz~16kHz octave or 1/3 octave sound pressure. level.

Document data

International classification (ICS): 29.240.01.

Chinese classification (CCS): F20.

Estimated length of the Chinese original: 11,148 words.

Supersedes the earlier edition DL/T 501-1992.

Standards quoted by this document

GB 3096; GB/T 3241; GB/T 3785.1; GB/T 3785.2; GB/T 3947; GB/T 15173