

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 502.16-2006

Replacing DL/T 502-1992 Partial

**Analytical methods of steam and water in power plants. Part 16:
Determination of ammonia (Spectrometric method using
nessler reagent)
(English Translation)**

Issued on: May 6, 2006

Implemented on: October 1, 2006

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the boiler water and cooling water, ammonia method. This method is suitable for boiler water and cooling water ammonia content 0. 1mg/L ~ 3. 0mg/L water sample was measured.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 9,956 words.

Adopted international standard: ASTM D1426-1998, IDT.

Supersedes the earlier edition DL/T 502-1992 Partial.

Standards quoted by this document

DL/T 502.2; GB/T 6903