

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 502.21-2006

Replacing DL/T 502-1992 Partial

**Analytical methods of steam and water in power plants. Part 21:
Determination of chlorine residual (Colorimetric method)
(English Translation)**

Issued on: May 6, 2006

Implemented on: October 1, 2006

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the boiler water and cooling water Determination of residual chlorine. This section applies to the boiler water and cooling water, residual chlorine content of 0. 01mg/L ~ 2. 00mg/L water sample was measured.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 8,865 words.

Adopted international standard: JIS K0101-28.1-1998, IDT.

Supersedes the earlier edition DL/T 502-1992 Partial.

Standards quoted by this document

DL/T 502.2; GB/T 6903