

ICS 27.100
CCS F 24

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 502.3-2006

Replacing DL/T 502-1992

**Analytical methods of steam and water in power plants. Part 3:
Determination of total silicon (Spectrometric method by
conversion with hydrofluoric acid)
(English Translation)**

Issued on: May 6, 2006

Implemented on: October 1, 2006

Issued by: National Development and Reform Commission

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the boiler water and cooling water Determination of total method. Silicon content in this section 1mg/L ~ 5mg/L method is applicable to the determination of the raw water, clarified water and boiler water Determination of total, silicon content of less than 100?g/L method applies to the determination of demineralized water, water, condensate, Determination of silicon in full steam. On the silicon content of 0. 1mg/L ~ 1. 0mg/L in water samples can be used to change the method of sample size determination.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): F24.

Estimated length of the Chinese original: 10,142 words.

Supersedes the earlier edition DL/T 502-1992.

Standards quoted by this document

GB/T 6903; DL/T 502.2