

ICS 13.030.40
CCS J 88

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 5418-2009

**Code for construction and acceptance of flue gas
desulphurization absorber of thermal power plant**

火电厂烟气脱硫吸收塔施工及验收规程

(English Translation)

Issued on: July 22, 2009

Implemented on: December 1, 2009

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard specifies the thermal power plant FGD absorber construction and acceptance of the technical requirements. This standard applies to thermal power plant FGD in ordinary carbon steel as the main structural materials, glass flake resin or rubber lining anti-corrosion construction and acceptance of the absorber. The range includes the absorber tower casing, internals and all welded tower casing body attachments or structure.

Document data

International classification (ICS): 13.030.40.

Chinese classification (CCS): J88.

Estimated length of the Chinese original: 93,981 words.

Standards quoted by this document

GB/T 983; GB/T 985.1-2008; GB 4053.1; GB 4053.2; GB 4053.3; GB/T 4842; GB/T 5117; GB/T 5118; GB/T 5293; GB/T 8110; GB/T 8923.2; GB/T 10045; GB/T 12470; GB/T 14957; GB/T 17853; GB 18241.4; GB 50128; GB 50236; DL/T 679; DL/T 868; DL/T 869; DL 5009.1; DL/T 5072; HGJ 32-1990; HG/T 2537; HG/T 3797; HG 20202; JB 4730; JB/T 4735; JB/T 4736; SJ/T 10743; HG/T 2640