

ICS 27.100
CCS P 60

DL

**INDUSTRY STANDARD OF THE
PEOPLE'S REPUBLIC OF CHINA**

DL/T 5508-2015

Code for design of gas-fired distributed energy station

燃气分布式供能站设计规范

(English Translation)

Issued on: July 1, 2015

Implemented on: December 1, 2015

Issued by: National Energy Administration

Table of Contents

What this standard covers	1
Document data	2
Standards quoted by this document	3

What this standard covers

This standard applies to the natural gas, biogas as fuel, while the output of cold, heat, electricity, new construction, expansion and reconstruction of distributed energy station design. The energy capacity of the prime mover of the building energy supply station should not exceed 10MW. The capacity of the prime mover of the regional energy supply station should not exceed 50MW.

Document data

International classification (ICS): 27.100.

Chinese classification (CCS): P60.

Estimated length of the Chinese original: 141,174 words.

Standards quoted by this document

JB/T 8953.2; JB/T 8953.3; GB 50011; GB 50013; GB 50016; GB 50019; GB 50028; GB 50034; GB 50040; GB 50049; GB 50050; GB 50051; GB 50054; GB 50057; GB 50058; GB 50060; GB/T 50062; GB/T 50063; GB 50065; GB/T 50102; GB/T 50109; GB 50116; GB 50140; GB 50144; GB 50176; GB 50183; GB 5018